

# Mid-Coast Council

PO Box 450

Forster NSW 2428

## Cooperook Sewage Treatment Plant

Emmo Lane

Cooperook NSW 2426

Environmental Protection licence number: 12583

Licence anniversary date

16th April

Abbreviations-

TSS: Total Suspended Solids

BOD: Biochemical Oxygen Demand

## EPA Monitoring Point 2, Discharge Quality Monitoring

### Effluent Quality Monitoring Results

Monitoring frequency: monthly

Date sampled	Date obtained	pH	TSS (mg/L)	BOD (mg/L)	Faecal Coliforms (cfu/100ml)	Oil & Grease (mg/L)	Compliance
27/04/2021	13/May/21	7.4	2	2	2	5	yes
25/05/2021	7/05/2021	7.4	2	2	4	5	yes
22/06/2021	1/07/2021	7.4	6	4	4	5	yes
20/07/2021	2/08/2021	7.5	<2	2	<2	<5	yes
17/08/2021	24/08/2021	7.6	2	2	48	<5	yes
Concentration limits		100%ile	6.5-8.5	30	30	200	10
<b>Annual summary</b>							
	<b>minimum</b>	7.4	2	2	2	5	0
	<b>average</b>	7.46	3.00	2.40	14.50	5.00	#DIV/0!
	<b>maximum</b>	7.6	6	4	48	5	0

**Non-compliance comments:**