

Licence Variation



Licence - 3175

MID-COAST COUNCIL
ABN 44 961 208 161
2 BIRIPI WAY SOUTH 2430
TAREE NSW 2430

Attention: Craig Dowler

Notice Number 1612513
File Number EF13/3279
Date 05-Oct-2021

NOTICE OF VARIATION OF LICENCE NO. 3175

BACKGROUND

- A. MID-COAST COUNCIL (“the Licensee”) is the holder of Environment Protection Licence No. 3175 (“the Licence”) issued under the *Protection of the Environment Operations Act 1997* (“the Act”). The licence authorises the carrying out of activities at PLANT LOCATED AT MIDCOAST WATER TRAIL (OFF THE PINES ROAD), DARAWANK, NSW, 2428 (“the Premises”).
- B. The Licence includes a condition for a pollution reduction study (PRS 4) under condition U1. The condition required the Licensee to investigate reasons for elevated total phosphorus concentrations in treated effluent and measures to reduce phosphorus and submit an investigation report to the NSW Environment Protection Authority (EPA).
- C. On 16 July 2021, the EPA received a letter from the Licensee detailing the PRS 4 investigations and proposing a 90 percentile total phosphorus concentration limit of 4 mg/L for treated wastewater.
- D. The EPA has assessed the Licensees submission against a range of assessment criteria taking into consideration issues in relation to managing chemical dosing to reduce phosphorus against the impacts on sludge characteristics (biosolids) when agreeing to this limit and that there appeared to be discernible impacts on groundwater.
- E. This Notice removes condition U1 as complete and adds a total phosphorus concentration limit of 4mg/L and increases monitoring from quarterly to monthly which will enable better review by the EPA that the Licensee is meeting the 90 percentile limit.
- F. The EPA provided the draft Licence to the Licensee on 14 September 2021 for review.
- G. The Licensee provided a submission on the draft Licence on 28 September 2021 accepting the variation without changes and the EPA has issued the Licence.

Licence Variation



- H. This Notice does not authorise a significant increase in the environmental impact of the activities authorised or controlled by the licence.
- I. This variation has been undertaken with consideration of section 45 of the Act.

VARIATION OF LICENCE NO. 3175

1. By this notice the EPA varies licence No. 3175. The attached licence document contains all variations that are made to the licence by this notice.
2. The following variations have been made to the licence:

Limit conditions

- L3.4 - (existing) added phosphorus limit

Monitoring Conditions

- M2.2 - (existing) changed quarterly monitoring to monthly monitoring

Pollution Studies

- U1 - (Existing) removed as completed

.....
Natasha Ryan
Acting Unit Head
Environment Protection Authority
(by Delegation)

INFORMATION ABOUT THIS NOTICE

- This notice is issued under section 58(5) of the Act.
- Details provided in this notice, along with an updated version of the licence, will be available on the EPA's Public Register (<http://www.epa.nsw.gov.au/prpoeo/index.htm>) in accordance with section 308 of the Act.

Appeals against this decision

- You can appeal to the Land and Environment Court against this decision. The deadline for lodging the appeal is 21 days after you were given notice of this decision.

When this notice begins to operate

Licence Variation



- The variations to the licence specified in this notice begin to operate immediately from the date of this notice, unless another date is specified in this notice.
- If an appeal is made against this decision to vary the licence and the Land and Environment Court directs that the decision is stayed the decision does not operate until the stay ceases to have effect or the Land and Environment Court confirms the decision or the appeal is withdrawn (whichever occurs first).

Environment Protection Licence

Licence - 3175

Licence Details

Number:	3175
Anniversary Date:	15-February

Licensee

MID-COAST COUNCIL

2 BIRIPI WAY SOUTH 2430

TAREE NSW 2430

Premises

HALLIDAYS POINT TREATMENT PLANT & SYSTEM

PLANT LOCATED AT MIDCOAST WATER TRAIL (OFF THE PINES ROAD)

DARAWANK NSW 2428

Scheduled Activity

Sewage treatment

Fee Based Activity

Sewage treatment processing by small plants

Scale

> 1000-5000 ML annual maximum volume of discharge

Contact Us

NSW EPA

4 Parramatta Square

12 Darcy Street

PARRAMATTA NSW 2150

Phone: 131 555

Email: info@epa.nsw.gov.au

Locked Bag 5022

PARRAMATTA NSW 2124



Environment Protection Licence

Licence - 3175

INFORMATION ABOUT THIS LICENCE	4
Dictionary	4
Responsibilities of licensee	4
Variation of licence conditions	4
Duration of licence	4
Licence review	4
Fees and annual return to be sent to the EPA	4
Transfer of licence	5
Public register and access to monitoring data	5
1 ADMINISTRATIVE CONDITIONS	6
A1 What the licence authorises and regulates	6
A2 Premises or plant to which this licence applies	6
A3 Information supplied to the EPA	6
2 DISCHARGES TO AIR AND WATER AND APPLICATIONS TO LAND	7
P1 Location of monitoring/discharge points and areas	7
3 LIMIT CONDITIONS	10
L1 Pollution of waters	10
L2 Load limits	10
L3 Concentration limits	10
L4 Volume and mass limits	11
L5 Waste	11
L6 Potentially offensive odour	12
4 OPERATING CONDITIONS	12
O1 Activities must be carried out in a competent manner	12
O2 Maintenance of plant and equipment	12
O3 Emergency response	13
O4 Processes and management	13
O5 Other operating conditions	14
5 MONITORING AND RECORDING CONDITIONS	14
M1 Monitoring records	14
M2 Requirement to monitor concentration of pollutants discharged	14
M3 Testing methods - concentration limits	16
M4 Testing methods - load limits	16
M5 Recording of pollution complaints	16
M6 Telephone complaints line	16



Environment Protection Licence

Licence - 3175

M7	Requirement to monitor volume or mass	17
M8	Requirement to record bypass incidents from sewage treatment plants	17
M9	Other monitoring and recording conditions	18
6	REPORTING CONDITIONS	18
R1	Annual return documents	18
R2	Notification of environmental harm	19
R3	Written report	20
R4	Other notifications	20
R5	Annual system performance report	24
7	GENERAL CONDITIONS	22
G1	Copy of licence kept at the premises or plant	22
G2	Contact number for incidents and responsible employees	22
G3	Signage	22
G4	Other general conditions	22
	DICTIONARY	23
	General Dictionary	23

Environment Protection Licence

Licence - 3175

Information about this licence

Dictionary

A definition of terms used in the licence can be found in the dictionary at the end of this licence.

Responsibilities of licensee

Separate to the requirements of this licence, general obligations of licensees are set out in the Protection of the Environment Operations Act 1997 ("the Act") and the Regulations made under the Act. These include obligations to:

- ensure persons associated with you comply with this licence, as set out in section 64 of the Act;
- control the pollution of waters and the pollution of air (see for example sections 120 - 132 of the Act);
- report incidents causing or threatening material environmental harm to the environment, as set out in Part 5.7 of the Act.

Variation of licence conditions

The licence holder can apply to vary the conditions of this licence. An application form for this purpose is available from the EPA.

The EPA may also vary the conditions of the licence at any time by written notice without an application being made.

Where a licence has been granted in relation to development which was assessed under the Environmental Planning and Assessment Act 1979 in accordance with the procedures applying to integrated development, the EPA may not impose conditions which are inconsistent with the development consent conditions until the licence is first reviewed under Part 3.6 of the Act.

Duration of licence

This licence will remain in force until the licence is surrendered by the licence holder or until it is suspended or revoked by the EPA or the Minister. A licence may only be surrendered with the written approval of the EPA.

Licence review

The Act requires that the EPA review your licence at least every 5 years after the issue of the licence, as set out in Part 3.6 and Schedule 5 of the Act. You will receive advance notice of the licence review.

Fees and annual return to be sent to the EPA

For each licence fee period you must pay:

- an administrative fee; and
- a load-based fee (if applicable).



Environment Protection Licence

Licence - 3175

The EPA publication “A Guide to Licensing” contains information about how to calculate your licence fees. The licence requires that an Annual Return, comprising a Statement of Compliance and a summary of any monitoring required by the licence (including the recording of complaints), be submitted to the EPA. The Annual Return must be submitted within 60 days after the end of each reporting period. See condition R1 regarding the Annual Return reporting requirements.

Usually the licence fee period is the same as the reporting period.

Transfer of licence

The licence holder can apply to transfer the licence to another person. An application form for this purpose is available from the EPA.

Public register and access to monitoring data

Part 9.5 of the Act requires the EPA to keep a public register of details and decisions of the EPA in relation to, for example:

- licence applications;
- licence conditions and variations;
- statements of compliance;
- load based licensing information; and
- load reduction agreements.

Under s320 of the Act application can be made to the EPA for access to monitoring data which has been submitted to the EPA by licensees.

This licence is issued to:

MID-COAST COUNCIL
2 BIRIPI WAY SOUTH 2430
TAREE NSW 2430

subject to the conditions which follow.

Environment Protection Licence

Licence - 3175

1 Administrative Conditions

A1 What the licence authorises and regulates

A1.1 This licence authorises the carrying out of the scheduled activities listed below at the premises specified in A2. The activities are listed according to their scheduled activity classification, fee-based activity classification and the scale of the operation.

Unless otherwise further restricted by a condition of this licence, the scale at which the activity is carried out must not exceed the maximum scale specified in this condition.

Scheduled Activity	Fee Based Activity	Scale
Sewage treatment	Sewage treatment processing by small plants	> 1000 - 5000 ML annual maximum volume of discharge

A1.2 The objectives of this licence are to:

- prevent as far as practicable sewage overflows and sewage treatment plant bypasses;
- require proper and efficient management of the system to minimise harm to the environment and public health; and
- require practical measures to be taken to protect the environment and public health from sewage overflows and sewage treatment plant effluent.

A1.3 This licence is to be construed in a manner that will promote the objectives referred to in the condition above.

A2 Premises or plant to which this licence applies

A2.1 The licence applies to the following premises:

Premises Details
HALLIDAYS POINT TREATMENT PLANT & SYSTEM
PLANT LOCATED AT MIDCOAST WATER TRAIL (OFF THE PINES ROAD)
DARAWANK
NSW 2428
LOT 2 DP 729774, LOT 8 DP 788364, LOT 9 DP 788364, LOT 1 DP 1102051
THE PREMISES ALSO INCLUDES THE TUNCURRY RETICULATION SYSTEM, THE TUNCURRY EFFLUENT REUSE PLANT AT GREY GUM ROAD (LOT 2, DP729774), THE TUNCURRY EXFILTRATION PONDS, AND THE NABIAC STP AND RETICULATION SYSTEM OWNED AND OPERATED BY THE LICENSEE, THAT ARE ASSOCIATED WITH THE SEWAGE TREATMENT PLANT AND DISPOSAL SYSTEM IDENTIFIED ABOVE.

A3 Information supplied to the EPA

Environment Protection Licence

Licence - 3175

- A3.1 Works and activities must be carried out in accordance with the proposal contained in the licence application, except as expressly provided by a condition of this licence.

In this condition the reference to "the licence application" includes a reference to:

- the applications for any licences (including former pollution control approvals) which this licence replaces under the Protection of the Environment Operations (Savings and Transitional) Regulation 1998; and
- the licence information form provided by the licensee to the EPA to assist the EPA in connection with the issuing of this licence.

2 Discharges to Air and Water and Applications to Land

P1 Location of monitoring/discharge points and areas

- P1.1 The following points referred to in the table are identified in this licence for the purposes of the monitoring and/or the setting of limits for discharges of pollutants to water from the point.

Water and land

EPA Identification no.	Type of Monitoring Point	Type of Discharge Point	Location Description
1	Discharge to waters	Discharge to waters	Outlet of the UV treatment system at Hallidays Point STP, shown generally on the drawing titled "Hallidays Point Groundwater Sampling Points", saved as EPA file DOC19/132282.
2	Inflow volume monitoring		Flow meter totaliser immediately after Inlet Works before Anoxic Tank at the Hallidays Point STP, shown generally on the drawing titled "Hallidays Point Groundwater Sampling Points", saved as EPA file DOC19/132282.
4	Groundwater quality monitoring		EPA ID04, shown on the drawing titled "Hallidays Point Groundwater Sampling Points", saved as EPA file DOC19/132282. Previously referred to as HP2A.
6	Groundwater quality monitoring		EPA ID06, shown on the drawing titled "Hallidays Point Groundwater Sampling Points", saved as EPA file DOC19/132282. Previously referred to as HP4.
8	Groundwater quality monitoring		EPA ID08, shown on the drawing titled "Hallidays Point Groundwater Sampling Points", saved as EPA file DOC19/132282. Previously referred to as HP6.

Environment Protection Licence

Licence - 3175

10	Groundwater quality monitoring	EPA ID10, shown on the drawing titled "Hallidays Point Groundwater Sampling Points", saved as EPA file DOC19/132282. Previously referred to as HP2B.
11	Groundwater quality monitoring	EPA ID11, shown on the drawing titled "Hallidays Point Groundwater Sampling Points", saved as EPA file DOC19/132282. Previously referred to as HP7.
12	Groundwater quality monitoring	EPA ID12, shown on the drawing titled "Hallidays Point Groundwater Sampling Points", saved as EPA file DOC19/132282. Previously referred to as HP8.
13	Groundwater quality monitoring	EPA ID13, shown on the drawing titled "Hallidays Point Groundwater Sampling Points", saved as EPA file DOC19/132282. Previously referred to as HP9.
14	Groundwater quality monitoring	EPA ID14, shown on the drawing titled "Hallidays Point Groundwater Sampling Points", saved as EPA file DOC19/132282. Previously referred to as HP10.
16	Groundwater quality monitoring	EPA ID16, shown on the drawing titled "Hallidays Point Groundwater Sampling Points", saved as EPA file DOC19/132282. Previously referred to as HP13.
17	Groundwater quality monitoring	EPA ID17, shown on the drawing titled "Hallidays Point Groundwater Sampling Points", saved as EPA file DOC19/132282. Previously referred to as HP14.
18	Groundwater quality monitoring	EPA ID18, shown on the drawing titled "Hallidays Point Groundwater Sampling Points", saved as EPA file DOC19/132282. Previously referred to as HP15.
19	Groundwater quality monitoring	EPA ID19, shown on the drawing titled "Hallidays Point Groundwater Sampling Points", saved as EPA file DOC19/132282. Previously referred to as HP16.
20	Groundwater quality monitoring	EPA ID20, shown on the drawing titled "Hallidays Point Groundwater Sampling Points", saved as EPA file DOC19/132282. Previously referred to as HP17.
22	Groundwater quality monitoring	EPA ID22, shown on the drawing titled "Hallidays Point Groundwater Sampling Points", saved as EPA file DOC19/132282. Previously referred to as HP19.

Environment Protection Licence

Licence - 3175

23	Groundwater quality monitoring		EPA ID23, shown on the drawing titled "Hallidays Point Groundwater Sampling Points", saved as EPA file DOC19/132282. Previously referred to as HP20.
24	Groundwater quality monitoring		EPA ID24, shown on the drawing titled "Hallidays Point Groundwater Sampling Points", saved as EPA file DOC19/132282. Previously referred to as HP21.
25	Groundwater quality monitoring		EPA ID25, shown on the drawing titled "Hallidays Point Groundwater Sampling Points", saved as EPA file DOC19/132282. Previously referred to as HP22.
26	Groundwater quality monitoring		EPA ID26, shown on the drawing titled "Hallidays Point Groundwater Sampling Points", saved as EPA file DOC19/132282. Previously referred to as HP23.
27	Groundwater quality monitoring		EPA ID27, shown on the drawing titled "Hallidays Point Groundwater Sampling Points", saved as EPA file DOC19/132282. Previously referred to as HP24.
28	Discharge to waters	Discharge to waters	EPA ID28, Tuncurry exfiltration ponds, Grey Gum Road Tuncurry, shown on the drawing titled "Hallidays Point EPA licence sample points", saved as EPA file DOC19/132282.
29	Groundwater Quality Monitoring		EPA ID29, shown on the drawing titled "Hallidays Point EPA licence sample points", saved as EPA file DOC19/132282. Previously referred to as TU14.
30	Groundwater Quality Monitoring		EPA ID30, shown on the drawing titled "Hallidays Point EPA licence sample points", saved as EPA file DOC19/132282. Previously referred to as TU17.
31	Groundwater Quality Monitoring		EPA ID31, shown on the drawing titled "Hallidays Point EPA licence sample points", saved as EPA file DOC19/132282. Previously referred to as TU5.
32	Groundwater Quality Monitoring		EPA ID32, shown on the drawing titled "Hallidays Point EPA licence sample points", saved as EPA file DOC19/132282. Previously referred to as TU6.

Environment Protection Licence

Licence - 3175

3 Limit Conditions

L1 Pollution of waters

- L1.1 Except as may be expressly provided in any other condition of this licence, the licensee must comply with section 120 of the Protection of the Environment Operations Act 1997.
- L1.2 The licensee may only discharge untreated or partially treated sewage from the sewage treatment plant and/or the reticulation system subject to the conditions of this licence, including Sections O1 and O2.

L2 Load limits

- L2.1 The actual load of an assessable pollutant discharged from the premises during the reporting period must not exceed the load limit specified for the assessable pollutant in the table below.
- L2.2 The actual load of an assessable pollutant must be calculated in accordance with the relevant load calculation protocol.

Assessable Pollutant	Load limit (kg)
BOD (Enclosed Water)	15195.00
Nitrogen (total) (Enclosed Water)	14355.00
Oil and Grease (Enclosed Water)	5429.00
Phosphorus (total) (Enclosed Water)	6580.00
Total suspended solids (Enclosed Water)	28694.00

Note: The load limits referred to in condition L2.1 do not apply to discharges from the reticulation system.

Note: An assessable pollutant is a pollutant which affects the licence fee payable for the licence.

L3 Concentration limits

- L3.1 For each monitoring/discharge point or utilisation area specified in the table below (by a point number), the concentration of a pollutant discharged at that point, or applied to that area, must not exceed the concentration limits specified for that pollutant in the table.
- L3.2 Where a pH quality limit is specified in the table, the specified percentage of samples must be within the specified ranges.
- L3.3 To avoid any doubt, this condition does not authorise the pollution of waters by any pollutant other than those specified in the table.
- L3.4 Water and/or Land Concentration Limits

Environment Protection Licence

Licence - 3175

POINT 1

Pollutant	Units of Measure	50 percentile concentration limit	90 percentile concentration limit	3DGM concentration limit	100 percentile concentration limit
BOD	milligrams per litre				20
Nitrogen (ammonia)	milligrams per litre				2
Nitrogen (total)	milligrams per litre				10
Oil and Grease	milligrams per litre				10
Phosphorus (total)	milligrams per litre		4		
Total suspended solids	milligrams per litre				20

L4 Volume and mass limits

- L4.1 For each discharge point or utilisation area specified below (by a point number), the volume/mass of:
- liquids discharged to water; or;
 - solids or liquids applied to the area;
- must not exceed the volume/mass limit specified for that discharge point or area.

Point	Unit of Measure	Volume/Mass Limit
1	kilolitres per day	33600
28	kilolitres per day	3000

Note: The monitoring at Point 2 is used to determine compliance with the limits at Point 1.

L5 Waste

- L5.1 The licensee must not cause, permit or allow any waste generated outside the premises to be received at the premises for storage, treatment, processing, reprocessing or disposal or any waste generated at the premises to be disposed of at the premises, except as expressly permitted by the licence.
- L5.2 This condition only applies to the storage, treatment, processing, reprocessing or disposal of waste at the premises if those activities require an environment protection licence.
- L5.3 The licensee may receive and/or transfer sewage and liquid waste generated outside the premises for treatment, processing or reprocessing at the premises. The licensee must take reasonable steps to ensure



Environment Protection Licence

Licence - 3175

that sewage and liquid waste received at the premises has been lawfully discharged in accordance with a trade waste agreement or customer contract (as applicable) in force between the licensee and the generator of the waste. The licensee must treat, process or reprocess the sewage and liquid waste in accordance with this licence prior to discharge from the premises.

- L5.4 The licensee may receive, store, treat, process or reprocess and/or transfer at the premises sewage products generated or stored outside the premises by the licensee's other sewage treatment systems. Sewage products must be received, treated, processed or reprocessed in accordance with this licence.

L6 Potentially offensive odour

- L6.1 No condition in this licence identifies a potentially offensive odour for the purposes of section 129 of the Protection of the Environment Operations Act 1997.

Note: Section 129 of the Protection of the Environment Operations Act 1997 provides that the licensee must not cause or permit the emission of any offensive odour from the premises but provides a defence if the emission is identified in the relevant environment protection licence as a potentially offensive odour and the odour was emitted in accordance with the conditions of a licence directed at minimising odour.

4 Operating Conditions

O1 Activities must be carried out in a competent manner

- O1.1 Licensed activities must be carried out in a competent manner.

This includes:

- a) the processing, handling, movement and storage of materials and substances used to carry out the activity; and
- b) the treatment, storage, processing, reprocessing, transport and disposal of waste generated by the activity.

Note: The requirements of O1.1 apply to the whole of the premises, including the reticulation system.

O2 Maintenance of plant and equipment

- O2.1 All plant and equipment installed at the premises or used in connection with the licensed activity:
- a) must be maintained in a proper and efficient condition; and
 - b) must be operated in a proper and efficient manner.

Note: The requirements of O2.1 apply to the whole of the premises, including the reticulation system.

- O2.2 For the purposes of this condition, "plant and equipment" includes drainage systems, infrastructure, pollution control equipment and fuel burning equipment, but does not refer to equipment which has been decommissioned but is still on site.

Environment Protection Licence

Licence - 3175

O3 Emergency response

- O3.1 In the event of an overflow or bypass that harms or is likely to harm the environment, the licensee must use all practicable measures to minimise the impact of the overflow or bypass on the environment and public health. These measures are to be implemented as soon as practical after the licensee or one of the licensee's employees or agents becomes aware of the overflow or bypass.

Note: The licensee must maintain, and implement as necessary, a current Pollution Incident Response Management Plan (PIRMP) for the premises. The PIRMP must be developed in accordance with the requirements in Part 5.7A of the POEO Act and regulations. The licensee must keep the PIRMP on the premises at all times. The PIRMP must document systems and procedures to deal with all types of incidents (e.g. spills, explosions or fires) that may occur at the premises or that may be associated with activities that occur at the premises and which are likely to cause harm to the environment.

The PIRMP must be tested at least annually or following a pollution incident.

O4 Processes and management

- O4.1 Sewage or effluent must not be discharged from point(s) 1 unless it has been treated in accordance with the requirements of the table below.

Required Treatment Process	Flow Range
Screening and oxidation ponding	All liquid waste inflow

Note: The flows noted in the table above are the inflows to the premises' sewage treatment plant(s).

- O4.2 However the licensee is not taken to have breached this condition if the licensee can demonstrate:
- the failure to treat the liquid waste as required was solely as a result of a failure of the power supply to the premises, or a failure of essential equipment;
 - the failure of power supply or equipment could not reasonably have been prevented; and
 - normal operating conditions were restored as soon as possible after the power supply failure or the failure of essential equipment.

- O4.3 The licensee must ensure that any extensions to the reticulation system after January 2004 are planned, designed, constructed and installed to prevent as far as practicable overflows from the premises.

Note: "The premises" includes both the new and the previously existing parts of the sewage treatment system.

- O4.4 Biosolids at the premises must be stored, treated, processed, classified, transported and disposed in accordance with the biosolids guidelines, or as otherwise approved in writing by the EPA.
- O4.5 The licensee must ensure that any extension to the reticulation system is planned, designed, constructed and installed to prevent as far as practicable discharges of sewage or partially treated sewage from the premises.

O4.6 Bunding

All above ground tanks containing material that is likely to cause environmental harm must be bunded or have

Environment Protection Licence

Licence - 3175

an alternative spill containment system in place.

Bunds must:

- a) have walls and floors constructed of impervious materials;
- b) be of sufficient capacity to contain 110% of the volume of the tank (or 110% volume of the largest tank where a group of tanks are installed);
- c) have floors graded to a collection sump; and
- d) not have a drain valve incorporated in the bund structure,

or be constructed and operated in a manner that achieves the same environmental outcome.

O5 Other operating conditions

O5.1 Prohibition on acceptance of pesticides

The licensee must not consent to the receipt of organochlorine pesticides (including dieldrin, heptachlor and chlordane) into the sewage treatment system after \$Parameter1\$.

O5.2 New sewage pumping stations

Dry weather overflows resulting in pollution of waters from any sewage pumping station(s) installed within the sewage treatment system after January 2004 are not permitted.

5 Monitoring and Recording Conditions

M1 Monitoring records

- M1.1 The results of any monitoring required to be conducted by this licence or a load calculation protocol must be recorded and retained as set out in this condition.
- M1.2 All records required to be kept by this licence must be:
- a) in a legible form, or in a form that can readily be reduced to a legible form;
 - b) kept for at least 4 years after the monitoring or event to which they relate took place; and
 - c) produced in a legible form to any authorised officer of the EPA who asks to see them.
- M1.3 The following records must be kept in respect of any samples required to be collected for the purposes of this licence:
- a) the date(s) on which the sample was taken;
 - b) the time(s) at which the sample was collected;
 - c) the point at which the sample was taken; and
 - d) the name of the person who collected the sample.

M2 Requirement to monitor concentration of pollutants discharged

- M2.1 For each monitoring/discharge point or utilisation area specified below (by a point number), the licensee must monitor (by sampling and obtaining results by analysis) the concentration of each pollutant specified in

Environment Protection Licence

Licence - 3175

Column 1. The licensee must use the sampling method, units of measure, and sample at the frequency, specified opposite in the other columns:

M2.2 Water and/ or Land Monitoring Requirements

POINT 1

Pollutant	Units of measure	Frequency	Sampling Method
Biochemical oxygen demand	milligrams per litre	Once a month (min. of 4 weeks)	Representative sample
Conductivity	millisiemens per centimetre	Quarterly	Representative sample
Faecal Coliforms	colony forming units per 100 millilitres	Quarterly	Representative sample
Nitrate + nitrite (oxidised nitrogen)	milligrams per litre	Quarterly	Representative sample
Nitrogen (ammonia)	milligrams per litre	Quarterly	Representative sample
Nitrogen (total)	milligrams per litre	Quarterly	Representative sample
Oil and Grease	milligrams per litre	Once a month (min. of 4 weeks)	Representative sample
Phosphorus (total)	milligrams per litre	Once a month (min. of 4 weeks)	Representative sample
TKN-N	milligrams per litre	Quarterly	Representative sample
Total suspended solids	milligrams per litre	Once a month (min. of 4 weeks)	Representative sample

POINT 4,6,8,10,11,12,13,14,16,17,18,19,20,22,23,24,25,26,27,29,30,31,32

Pollutant	Units of measure	Frequency	Sampling Method
Biochemical oxygen demand	milligrams per litre	Quarterly	Representative sample
Conductivity	millisiemens per centimetre	Quarterly	Representative sample
Faecal Coliforms	colony forming units per 100 millilitres	Quarterly	Representative sample
Nitrate + nitrite (oxidised nitrogen)	milligrams per litre	Quarterly	Representative sample
Nitrogen (ammonia)	milligrams per litre	Quarterly	Representative sample
Nitrogen (total)	milligrams per litre	Quarterly	Representative sample
Phosphorus (total)	milligrams per litre	Quarterly	Representative sample
TKN-N	milligrams per litre	Quarterly	Representative sample

POINT 28

Pollutant	Units of measure	Frequency	Sampling Method
Biochemical oxygen demand	milligrams per litre	Monthly during discharge	Representative sample
Faecal Coliforms	colony forming units per 100 millilitres	Monthly during discharge	Representative sample
Nitrogen (total)	milligrams per litre	Monthly during discharge	Representative sample

Environment Protection Licence

Licence - 3175

Oil and Grease	milligrams per litre	Monthly during discharge	Representative sample
Phosphorus (total)	milligrams per litre	Monthly during discharge	Representative sample
Total suspended solids	milligrams per litre	Monthly during discharge	Representative sample

M3 Testing methods - concentration limits

M3.1 Subject to any express provision to the contrary in this licence, monitoring for the concentration of a pollutant discharged to waters or applied to a utilisation area must be done in accordance with the Approved Methods Publication unless another method has been approved by the EPA in writing before any tests are conducted.

M4 Testing methods - load limits

Note: Division 3 of the *Protection of the Environment Operations (General) Regulation 2021* requires that monitoring of actual loads of assessable pollutants listed in L2.2 must be carried out in accordance with the relevant load calculation protocol set out for the fee-based activity classification listed in the Administrative Conditions of this licence.

M5 Recording of pollution complaints

M5.1 The licensee must keep a legible record of all complaints made to the licensee or any employee or agent of the licensee in relation to pollution arising from any activity to which this licence applies.

M5.2 The record must include details of the following:

- a) the date and time of the complaint;
- b) the method by which the complaint was made;
- c) any personal details of the complainant which were provided by the complainant or, if no such details were provided, a note to that effect;
- d) the nature of the complaint;
- e) the action taken by the licensee in relation to the complaint, including any follow-up contact with the complainant; and
- f) if no action was taken by the licensee, the reasons why no action was taken.

M5.3 The record of a complaint must be kept for at least 4 years after the complaint was made.

M5.4 The record must be produced to any authorised officer of the EPA who asks to see them.

M6 Telephone complaints line

M6.1 The licensee must operate during its operating hours a telephone complaints line for the purpose of receiving any complaints from members of the public in relation to activities conducted at the premises or by the vehicle or mobile plant, unless otherwise specified in the licence.

Environment Protection Licence

Licence - 3175

- M6.2 The licensee must notify the public of the complaints line telephone number and the fact that it is a complaints line so that the impacted community knows how to make a complaint.
- M6.3 The preceding two conditions do not apply until 3 months after: the date of the issue of this licence.
- M6.4 For the purpose of condition M5.1, operating hours are defined as twenty-four hours a day, seven days a week.
- M6.5 The public notification referred to in condition M5.2 must include specific reference to the fact that the complaints line may be used by the community for the reporting of overflows.

M7 Requirement to monitor volume or mass

- M7.1 For each discharge point or utilisation area specified below, the licensee must monitor:
- the volume of liquids discharged to water or applied to the area;
 - the mass of solids applied to the area;
 - the mass of pollutants emitted to the air;
- at the frequency and using the method and units of measure, specified below.

POINT 2

Frequency	Unit of Measure	Sampling Method
Continuous	kilolitres per day	Flow meter and continuous logger

POINT 28

Frequency	Unit of Measure	Sampling Method
Continuous	kilolitres per day	Flow meter and continuous logger

- M7.2 In the event that the licensee cannot comply with a volume monitoring method as required by this licence solely due to the failure or malfunction of essential monitoring equipment, volume may be estimated using another agreed method approved in writing by the EPA. This provision only applies for the duration of the failure or malfunction. The licensee is to rectify the failure or malfunction as soon as practicable.
- M7.3 The licensee must:
- submit in writing to the EPA a proposal for a method of volume estimation; or
 - use a method of volume estimation already approved in writing by the EPA,
- to be used in the event that essential monitoring equipment referred to in the previous condition has failed or malfunctioned.

M8 Requirement to record bypass incidents from sewage treatment plants

- M8.1 The licensee must record the following details in respect of each bypass of any of the appropriate treatment processes required by condition O3 which may be reasonably expected to adversely affect the quality of the

Environment Protection Licence

Licence - 3175

final discharge:

- a) the EPA point identification number through which the bypass discharged;
- b) the date, estimated start time and estimated duration of the bypass;
- c) the estimated volume of the bypass;
- d) the level of treatment of the sewage at the STP prior to discharge;
- e) the probable cause of the bypass;
- f) any actions taken to stop the bypass happening; and
- g) any actions taken to prevent the bypass happening again.

M8.2 The licensee must record the following details in relation to each observed or reported overflow from the reticulation system and from the sewage treatment plant:

- a) the location of the overflow;
- b) the date, estimated start time and estimated duration of the overflow;
- c) the estimated volume of the overflow;
- d) a description of the receiving environment of the overflow;
- e) classification as a dry or wet weather overflow;
- f) the probable cause of the overflow;
- g) any actions taken to stop the overflow happening;
- h) any actions taken to clean up the overflow; and
- i) any actions taken to prevent the overflow happening again.

M9 Other monitoring and recording conditions

M9.1 Biosolids at the premises must be recorded, monitored and classified in accordance with the Biosolids Guidelines, to the extent that those Guidelines are applicable, or as otherwise approved in writing by the EPA.

M9.2 If biosolids are removed from the premises, the licensee must record the:

- a) date;
- b) estimated weight of biosolids;
- c) identity of the person removing biosolids.

6 Reporting Conditions

R1 Annual return documents

R1.1 The licensee must complete and supply to the EPA an Annual Return in the approved form comprising:

1. a Statement of Compliance,
2. a Monitoring and Complaints Summary,
3. a Statement of Compliance - Licence Conditions,
4. a Statement of Compliance - Load based Fee,
5. a Statement of Compliance - Requirement to Prepare Pollution Incident Response Management Plan,
6. a Statement of Compliance - Requirement to Publish Pollution Monitoring Data; and
7. a Statement of Compliance - Environmental Management Systems and Practices.

Environment Protection Licence

Licence - 3175

At the end of each reporting period, the EPA will provide to the licensee notification that the Annual Return is due.

- R1.2 An Annual Return must be prepared in respect of each reporting period, except as provided below.
- R1.3 Where this licence is transferred from the licensee to a new licensee:
- the transferring licensee must prepare an Annual Return for the period commencing on the first day of the reporting period and ending on the date the application for the transfer of the licence to the new licensee is granted; and
 - the new licensee must prepare an Annual Return for the period commencing on the date the application for the transfer of the licence is granted and ending on the last day of the reporting period.
- R1.4 Where this licence is surrendered by the licensee or revoked by the EPA or Minister, the licensee must prepare an Annual Return in respect of the period commencing on the first day of the reporting period and ending on:
- in relation to the surrender of a licence - the date when notice in writing of approval of the surrender is given; or
 - in relation to the revocation of the licence - the date from which notice revoking the licence operates.
- R1.5 The Annual Return for the reporting period must be supplied to the EPA via eConnect *EPA* or by registered post not later than 60 days after the end of each reporting period or in the case of a transferring licence not later than 60 days after the date the transfer was granted (the 'due date').
- R1.6 Where the licensee is unable to complete a part of the Annual Return by the due date because the licensee was unable to calculate the actual load of a pollutant due to circumstances beyond the licensee's control, the licensee must notify the EPA in writing as soon as practicable, and in any event not later than the due date. The notification must specify:
- the assessable pollutants for which the actual load could not be calculated; and
 - the relevant circumstances that were beyond the control of the licensee.
- R1.7 The licensee must retain a copy of the Annual Return supplied to the EPA for a period of at least 4 years after the Annual Return was due to be supplied to the EPA.
- R1.8 Within the Annual Return, the Statements of Compliance must be certified and the Monitoring and Complaints Summary must be signed by:
- the licence holder; or
 - by a person approved in writing by the EPA to sign on behalf of the licence holder.

Note: The term "reporting period" is defined in the dictionary at the end of this licence. Do not complete the Annual Return until after the end of the reporting period.

Note: An application to transfer a licence must be made in the approved form for this purpose.

R2 Notification of environmental harm

R2.1 Notifications must be made by telephoning the Environment Line service on 131 555.

R2.2 The licensee must provide written details of the notification to the EPA within 7 days of the date on which they

Environment Protection Licence

Licence - 3175

became aware of the incident.

Note: The licensee or its employees must notify all relevant authorities of incidents causing or threatening material harm to the environment immediately after the person becomes aware of the incident in accordance with the requirements of Part 5.7 of the Act.

R3 Written report

- R3.1 Where an authorised officer of the EPA suspects on reasonable grounds that:
- where this licence applies to premises, an event has occurred at the premises; or
 - where this licence applies to vehicles or mobile plant, an event has occurred in connection with the carrying out of the activities authorised by this licence, and the event has caused, is causing or is likely to cause material harm to the environment (whether the harm occurs on or off premises to which the licence applies), the authorised officer may request a written report of the event.
- R3.2 The licensee must make all reasonable inquiries in relation to the event and supply the report to the EPA within such time as may be specified in the request.
- R3.3 The request may require a report which includes any or all of the following information:
- the cause, time and duration of the event;
 - the type, volume and concentration of every pollutant discharged as a result of the event;
 - the name, address and business hours telephone number of employees or agents of the licensee, or a specified class of them, who witnessed the event;
 - the name, address and business hours telephone number of every other person (of whom the licensee is aware) who witnessed the event, unless the licensee has been unable to obtain that information after making reasonable effort;
 - action taken by the licensee in relation to the event, including any follow-up contact with any complainants;
 - details of any measure taken or proposed to be taken to prevent or mitigate against a recurrence of such an event; and
 - any other relevant matters.
- R3.4 The EPA may make a written request for further details in relation to any of the above matters if it is not satisfied with the report provided by the licensee. The licensee must provide such further details to the EPA within the time specified in the request.

R4 Other notifications

- R4.1 Where either:
- sewage or partially treated sewage is discharged from the premises as a result of a bypass of the sewage treatment plant, or
 - an observed or reported overflow has occurred from the reticulation system, and overflow or bypass may pose a risk to public health, the licensee is to promptly give appropriate notification to any parties that are likely to be affected, including:
 - the potentially affected community,
 - the NSW Food Authority Shellfish Quality Assurance Program, where the bypass or overflow could have potential impacts on shellfish production; and

Environment Protection Licence

Licence - 3175

iii) the Department of Health.

R4.2 When the licensee notifies the Department of Health, or NSW Food Authority Shellfish Quality Assurance Program, of a bypass or overflow incident, the licensee must also notify the EPA by telephoning its Environment Line service on 131 555. Notifications are to be given as soon as practicable after the licensee, or one of the licensee's employees or agents becomes aware of the incident, and must include all relevant information required under conditions M8.1 or M8.2.

R4.3 Where sewage or partially treated sewage is discharged from the premises as a result of a bypass of the sewage treatment plant, the licensee must notify Beachwatch on (02) 9995 5344. Notifications are to be given as soon as practicable after the licensee or one of the licensee's employees or agents become aware of the incident, and must include all relevant information including the information required under condition M8.1.

Note: These reporting requirements are in addition to the licensee's general obligation as described in condition R2 to report incidents which cause or threaten material harm to the environment. A notification may satisfy the requirements of both R2 and R4.

R5 Annual system performance report

R5.1 The licensee must supply to the EPA an Annual System Performance Report not later than 60 days after the end of each reporting period.

R5.2 The report is to supplement the Annual Return and must include but need not be limited to:

- a) the 50 percentile, 90 percentile, 100 percentile and 3DGM values calculated from the monitoring data required by this licence for the reporting period for each pollutant which has corresponding concentration limits specified in this licence;
- b) the total amounts of biosolids, as classified in the Biosolids Guideline, disposed of on-site, off-site and to landfill during the reporting period;
- c) a diagram showing the major process elements, discharge points and monitoring points at the premises' sewage treatment plant(s), where there has been any significant change since the previous reporting period or this information has not been provided previously to the EPA;
- d) the number of dry and wet weather bypasses recorded over the reporting period (recorded in accordance with condition M7);
- e) a breakdown of the total number of complaints received by the licensee during the reporting period in relation to the premises into categories of "odours – sewage treatment plant", "odours – reticulation system", "water pollution – sewage treatment plant", "water pollution – reticulation system" and any other category indicated by the complaints;
- f) a summary of observed, reported or recorded wet weather overflows and observed, reported or recorded dry weather overflows and sewage treatment plant bypasses. These data are to be for the current reporting period and for the four previous twelve-month periods, for which data has been collected. Any significant actions taken to address bypasses or overflows are to be noted;
- g) the amount of rainfall measured at a rain gauge at the STP, or at the rain gauge closest to the centre of the catchment of the sewage treatment system, for each month of the reporting period; and
- h) a brief progress report on the implementation over the reporting period of actions specified in PRP100.

R5.3 The Annual System Performance Report must be presented in a format approved in writing by the EPA.

Environment Protection Licence

Licence - 3175

7 General Conditions

G1 Copy of licence kept at the premises or plant

- G1.1 A copy of this licence must be kept at the premises to which the licence applies.
- G1.2 The licence must be produced to any authorised officer of the EPA who asks to see it.
- G1.3 The licence must be available for inspection by any employee or agent of the licensee working at the premises.

Note: For the purposes of this condition, “the premises” refers to each Sewage Treatment Plant(s) described in condition A2.1.

G2 Contact number for incidents and responsible employees

- G2.1 The licensee must operate 24-hour telephone contact lines for the purpose of enabling the EPA to directly contact one or more representatives of the licensee who can:
- a) respond at all times to incidents relating to the premises; and
 - b) contact the licensee’s senior employees or agents authorised at all times to:
 - i) speak on behalf of the licensee; and
 - ii) provide any information or document required under this licence.
- G2.2 The licensee is to inform the EPA in writing of the appointment of any subsequent contact persons, or changes to the person’s contact details as soon as practicable and in any event within fourteen days of the appointment or change.

G3 Signage

- G3.1 The location of EPA point number(s) 1 and 2 must be clearly marked by signs that indicate the point identification number used in this licence and be located as close as practical to the point.

G4 Other general conditions

- G4.1 In the event of an overflow or bypass that harms or is likely to harm the environment, the licensee must use all practicable measures to minimise the impact of the overflow or bypass on the environment and public health. These measures are to be implemented as soon as practical after the licensee or one of the licensees employees or agents becomes aware of the overflow or bypass.

Environment Protection Licence

Licence - 3175

Dictionary

General Dictionary

3DGM [in relation to a concentration limit]	Means the three day geometric mean, which is calculated by multiplying the results of the analysis of three samples collected on consecutive days and then taking the cubed root of that amount. Where one or more of the samples is zero or below the detection limit for the analysis, then 1 or the detection limit respectively should be used in place of those samples
Act	Means the Protection of the Environment Operations Act 1997
activity	Means a scheduled or non-scheduled activity within the meaning of the Protection of the Environment Operations Act 1997
actual load	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 2009
AM	Together with a number, means an ambient air monitoring method of that number prescribed by the <i>Approved Methods for the Sampling and Analysis of Air Pollutants in New South Wales</i> .
AMG	Australian Map Grid
anniversary date	The anniversary date is the anniversary each year of the date of issue of the licence. In the case of a licence continued in force by the Protection of the Environment Operations Act 1997, the date of issue of the licence is the first anniversary of the date of issue or last renewal of the licence following the commencement of the Act.
annual return	Is defined in R1.1
Approved Methods Publication	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 2009
assessable pollutants	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 2009
BOD	Means biochemical oxygen demand
CEM	Together with a number, means a continuous emission monitoring method of that number prescribed by the <i>Approved Methods for the Sampling and Analysis of Air Pollutants in New South Wales</i> .
COD	Means chemical oxygen demand
composite sample	Unless otherwise specifically approved in writing by the EPA, a sample consisting of 24 individual samples collected at hourly intervals and each having an equivalent volume.
cond.	Means conductivity
environment	Has the same meaning as in the Protection of the Environment Operations Act 1997
environment protection legislation	Has the same meaning as in the Protection of the Environment Administration Act 1991
EPA	Means Environment Protection Authority of New South Wales.
fee-based activity classification	Means the numbered short descriptions in Schedule 1 of the Protection of the Environment Operations (General) Regulation 2009.
general solid waste (non-putrescible)	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997

Environment Protection Licence

Licence - 3175

flow weighted composite sample	Means a sample whose composites are sized in proportion to the flow at each composites time of collection.
general solid waste (putrescible)	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
grab sample	Means a single sample taken at a point at a single time
hazardous waste	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
licensee	Means the licence holder described at the front of this licence
load calculation protocol	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 2009
local authority	Has the same meaning as in the Protection of the Environment Operations Act 1997
material harm	Has the same meaning as in section 147 Protection of the Environment Operations Act 1997
MBAS	Means methylene blue active substances
Minister	Means the Minister administering the Protection of the Environment Operations Act 1997
mobile plant	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
motor vehicle	Has the same meaning as in the Protection of the Environment Operations Act 1997
O&G	Means oil and grease
percentile [in relation to a concentration limit of a sample]	Means that percentage [eg.50%] of the number of samples taken that must meet the concentration limit specified in the licence for that pollutant over a specified period of time. In this licence, the specified period of time is the Reporting Period unless otherwise stated in this licence.
plant	Includes all plant within the meaning of the Protection of the Environment Operations Act 1997 as well as motor vehicles.
pollution of waters [or water pollution]	Has the same meaning as in the Protection of the Environment Operations Act 1997
premises	Means the premises described in condition A2.1
public authority	Has the same meaning as in the Protection of the Environment Operations Act 1997
regional office	Means the relevant EPA office referred to in the Contacting the EPA document accompanying this licence
reporting period	For the purposes of this licence, the reporting period means the period of 12 months after the issue of the licence, and each subsequent period of 12 months. In the case of a licence continued in force by the Protection of the Environment Operations Act 1997, the date of issue of the licence is the first anniversary of the date of issue or last renewal of the licence following the commencement of the Act.
restricted solid waste	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
scheduled activity	Means an activity listed in Schedule 1 of the Protection of the Environment Operations Act 1997
special waste	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
TM	Together with a number, means a test method of that number prescribed by the <i>Approved Methods for the Sampling and Analysis of Air Pollutants in New South Wales</i> .



Environment Protection Licence

Licence - 3175

TSP	Means total suspended particles
TSS	Means total suspended solids
Type 1 substance	Means the elements antimony, arsenic, cadmium, lead or mercury or any compound containing one or more of those elements
Type 2 substance	Means the elements beryllium, chromium, cobalt, manganese, nickel, selenium, tin or vanadium or any compound containing one or more of those elements
utilisation area	Means any area shown as a utilisation area on a map submitted with the application for this licence
waste	Has the same meaning as in the Protection of the Environment Operations Act 1997
waste type	Means liquid, restricted solid waste, general solid waste (putrescible), general solid waste (non - putrescible), special waste or hazardous waste

Ms Nadia Kanhoush

Environment Protection Authority

(By Delegation)

Date of this edition: 07-August-2000

Environment Protection Licence

Licence - 3175

End Notes

- 1 Licence varied by notice 1013881, issued on 29-May-2002, which came into effect on 23-Jun-2002.
- 2 Licence varied by notice 1020538, issued on 17-Dec-2002, which came into effect on 11-Jan-2003.
- 3 Licence varied by notice 1029199, issued on 28-Aug-2003, which came into effect on 22-Sep-2003.
- 4 EPA Condition ID S40934 amended 13-08-04
- 5 Licence varied by notice 1062003, issued on 24-Aug-2006, which came into effect on 24-Aug-2006.
- 6 Licence varied by notice 1076058, issued on 06-Sep-2007, which came into effect on 06-Sep-2007.
- 7 Licence varied by correction to DEC file number, issued on 11-Sep-2007, which came into effect on 11-Sep-2007.
- 8 Condition A1.3 Not applicable varied by notice issued on <issue date> which came into effect on <effective date>
- 9 Licence varied by notice 1082383, issued on 29-Jan-2009, which came into effect on 29-Jan-2009.
- 10 Licence varied by notice 1513339 issued on 14-Feb-2014
- 11 Licence transferred through application 1554244 approved on 24-Jul-2017 , which came into effect on 01-Jul-2017
- 12 Licence varied by notice 1575839 issued on 08-Apr-2020
- 13 Licence varied by notice 1597474 issued on 15-Jul-2020