

Mid-Coast Council

PO Box 482

Taree NSW 2430

Lansdowne Sewage Treatment Plant

Off Central Lansdowne Rd

Lansdowne NSW 2426

Environmental Protection licence number: 12586

Licence anniversary date

16th April

Abbreviations-

TSS: Total Suspended Solids

BOD: Biochemical Oxygen Demand

EPA Monitoring Point 2,

Discharge Quality Monitoring

Effluent Quality Monitoring Results

Monitoring frequency: monthly

Date sampled	Date obtained	pH	TSS (mg/L)	BOD (mg/L)	Faecal Coliforms	Oil & Grease	Compliance
27/04/2021	5/05/2021	7.4	2	2	44	5	yes
25/05/2021	7/06/2021	7.4	3	2	28	5	yes
22/06/2021	1/07/2021	7.2	9	4	22	5	yes
20/07/2021	2/08/2021	7.5	2	3	54	5	yes
17/08/2021	24/08/2021	7.4	17	7	~36	<5	yes
14/09/2021	27/09/2021	7.6	6	3	6	<5	yes
12/10/2021	21/10/2021	7.6	7	4	8	<5	yes
9/11/2021	24/11/2021	7.4	6	14	8	<5	yes
7/12/2021	21/12/2021	7.5	3	<2	6	<5	yes
5/01/2022	20/01/2022	7.3	13	3	~12	<5	yes
1/02/2022	14/02/2022	7.6	<2	<2	<2	<5	yes
1/03/2022	17/03/2022	7	5	<2	~80	<5	yes
5/04/2022	27/04/2022	7.4	4	3	6	<5	yes

Concentration limits

100%ile

6.5-8.5

30

30

200

10

Annual summary

minimum
average
maximum

7.00
7.41
7.6

2
6.42
17

2
4.50
14

6
20.22
54

<5
<5
<5

Non-compliance comments: