

**Mid-Coast Council**PO Box 482  
Taree NSW 2430**Old Bar Sewage Treatment Plant**Saltwater Rd  
Old Bar NSW 2430

Environmental Protection licence number: 2391

Licence anniversary date 1-Jun

Abbreviations-

TSS: Total Suspended Solids

BOD: Biochemical Oxygen Demand

**EPA Monitoring Point 3,  
Discharge to waters****Effluent Quality Monitoring Results**

Monitoring frequency: monthly

Date sampled	Date obtained	pH	TSS (mg/L)	BOD (mg/L)	Faecal Coliforms	Nitrogen ammonia	Nitrogen total	Phosphorus total (mg/L)	Oil & Grease (mg/L)	Compliance
7/06/2022	17/06/2022	7.5	5	<2	4	8.42	9.57	0.75	<5	yes
5/07/2022	19/07/2022	7.4	5	<2	<4	0.45	1.28	0.29	<5	yes
2/08/2022	24/08/2022	7.2	<2	<2	<1	0.03	3.64	1.04	<5	yes
Concentration limits	90 %ile 100%ile	N/A N/A		N/A 20mg/L	N/A N/A	4mg/L 5mg/L	10mg/L 15mg/L	2mg/L 4mg/L		
<b>Annual summary</b>										
	minimum	7.2	5	0	4	0.03	1.28	0.29	0	
	average	7	5.00	#DIV/0!	4	2.97	4.83	0.69	#DIV/0!	
	maximum	7.5	5	0	4	8.42	9.57	1.04	0	

**Monthly Discharge Volume Monitoring Summary**

Monitoring frequency: daily

Discharge limit: 8050kL, 4025kL a day each to EPA Point 1 and 4

	No of readings	Min kL/day	Average (kL/day)	Max (kL/day)	Compliance
Jun-22	30	308	1331	2585	yes
Jul-22	31	358	1341	2189	yes
Aug-22	31				
Sep-22	30				
Oct-22	31				
Nov-22	30				
Dec-22	31				
Jan-23	31				
Feb-23	28				
Mar-23	31				
Apr-23	30				
May-23	31				

Non-compliance comments: