## **Mid-Coast Council**

PO Box 450

Forster NSW 2428

**Coopernook Sewage Treatment Plant** 

Emmo Lane

Coopernook NSW 2426

**Environmental Protection licence number: 12583** Licence anniversary date

Abbreviations-

TSS: Total Suspended Solids

**BOD: Biochemical Oxygen Demand** 

**EPA Monitoring Point 2, Discharge Quality Monitoring** 

16th April

Effluent Quality Monitoring Results								
Monitoring fre	equency: mont	:hly						
Date sampled	Date obtained	рН	TSS (mg/L)	BOD (mg/L)	Faecal Coliforms (cfu/100ml)	Oil & Grease (mg/L)		Compliance
6/05/2025	22/May/25	7.2	6	4	~<4	<5		yes
Concentration limits	100%ile	6.5-8.5	30	30	200	10		
		A	Annual summary					
	minimum	7.2	6	4	0	0		
	average maximum	7.20 7.2	6.00	4.00 4	#DIV/0! 0	#DIV/0! 0		

Non-compliance comments: