

Mid-Coast Council

PO Box 482
Taree NSW 2430
Lansdowne Sewage Treatment Plant
Off Central Lansdowne Rd
Lansdowne NSW 2426

Environmental Protection licence number: 12586

Licence anniversary date 16th April

Abbreviations-
TSS: Total Suspended Solids
BOD: Biochemical Oxygen Demand

EPA Monitoring Point 2,

Discharge Quality Monitoring

Effluent Quality Monitoring Results							
Monitoring frequency: monthly							
Date sampled	Date obtained	pH	TSS (mg/L)	BOD (mg/L)	Faecal Coliforms	Oil & Grease	Compliance
6/05/2025	22/05/2025	7.1	<2	<2	~4	<5	yes
3/06/2025	13/06/2025	7.2	2	<2	<2	<5	yes
							yes
							yes
							yes
							yes
							yes
							yes
							yes
							yes
							yes
							yes
							yes
							yes
							yes
Concentration limits		100%ile	6.5-8.5	30	30	200	10
Annual summary							
	minimum	7.10	2	0	0	<5	
	average	7.15	2.00	#DIV/0!	#DIV/0!	<5	
	maximum	7.2	2	0	0	<5	

Non-compliance comments: