

PO Box 482
Taree NSW 2428
Gloucester Sewage Treatment Plant
84 Showground Road
Gloucester NSW 2422

Abbreviations-
TSS: Total Suspended Solids
BOD: Biochemical Oxygen Demand

Environmental Protection licence number: 721

Licence anniversary date	1st December
---------------------------------	---------------------

EPA Monitoring Point 3

Discharge Quality to waters, Effluent quality monitoring

Effluent Quality Monitoring Results

Monitoring frequency: monthly

[illegible]

Note: exceedances with pH,TSS,BOD not considered a non compliance when chlorophyyll-a is greater than 100 ug/L

Concentration limits	100%ile	6.5-8.5	30	20	10	35
		Annual summary				
	minimum	6.9	15	5	0.14	2.51
	average	8	27	9	1.06	5.16
	maximum	8.9	63	17	4.04	8.47

EPA Monitoring Point 3 - Total outflow volume monitoring

discharge to waters

Monthly Volume Monitoring Summary

Monitoring frequency: daily

Discharge limit 6500kL

	No of readings	Min kL/day	Average (kL/day)	Max (kL/day)	Compliance
Dec-24	31	0	259	522	yes
Jan-25	31	0	1101	5502	yes
Feb-25	28	25.7	366	1048	yes
Mar-25	31	293	1292	4569	yes
Apr-25	30	358	1431	3793	yes
May-25	31				
Jun-25	30				
Jul-25	31				
Aug-25	31				
Sep-25	30				
Oct-25	31				
Nov-25	30				

Non-compliance comments: