

PO Box 482
Taree NSW 2430
Forster Wastewater Treatment Plant
Off Sweet Pea Road
Forster NSW 2428
Environmental Protection licence number
Licence Anniverserv: 6 th August

Abbreviations-
TSS: Total Suspended Solids
BOD: Biochemical Oxygen Demand
FC: Faecal coliforms

[illegible]

Relayvent for discharge to waters- EPA Id 1 ocean outfall Janies Corner

Monitoring frequency: daily
Discharge limit 23000kl

	No of readings	Average (kL/day)	Max (kL/day)	Compliance
Aug-23	31	4623	6946	yes
Sep-23	30	3966	6073	yes
Oct-23	31	4673	11590	yes
Nov-23	30	4406	6193	yes
Dec-23	31	4093	5424	yes
Jan-24	31	8835	21903	yes
Feb-24	28	4917	7334	yes
Mar-24	31	5721	10711	yes
Apr-24	30	7077	14232	yes
May-24	31	10489	23770	no
Jun-24	30			
Jul-24	31			

Non - compliances
May discharge- natural disaster flooding event